

# System Unit GARNET1230, FK-5-1-12 engineered extinguishing system units, 25 bar

File Number: EX28925

**COMPANY**

Utusan Deria Sdn Bhd

No. 18a, Jalan Au 5d/1, Taman Lembah Keramat  
Kuala Lumpur, Kuala Lumpur 54200 Malaysia

**SYSTEM UNIT INFO**

GARNET1230, FK-5-1-12 engineered extinguishing system units, 25 bar

Engineered, Halocarbon

CLEAN AGENT EXTINGUISHING SYSTEM UNITS	VALUE
Extinguishing Agent (ASHRAE Designation)	FK-5-1-12

MANUALS AND BULLETINS		
Part No.	Description	Date/Rev
GN1230MAL-0001	Installation, Design and Maintenance Manual	Rev 06 dated 2023-02

SYSTEM UNIT INFORMATION		
Operating Pressure at Temperature	Minimum Operating Temperature	Maximum Operating Temperature
25 bar at 21 °C (360 psig at 70 °F)	0 C (32 F)	50 C (122 F)

THESE INSTALLATIONS REQUIRE THE USE OF THE LISTEE'S FLOW CALCULATION SOFTWARE:
Software Name/Version
Garnet Engineered System Flow Calculation Software Version 4.00

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."